

STATE LOAD DESPATCH CENTER

AGENDA FOR 53rd MEETING Of State Level Co-ordination Forum

Date: 30/01/2018

Venue: SLDC

ITEM No:1. CONFIRMATION OF THE MINUTES OF 52nd SLCF MEETING HELD ON 21.11.2017.

The minutes was circulated vide memo no: **SLDC/How/109/1282** dated 04/12/2017 and the same was also published in the website(www.wbslhc.in). A corrigendum of the above MOM has also been published vide memo no: **SLDC/How/109/1366** dated 15/12/2017.

---- Members may please discuss.

ITEM No: 2. REVIEW OF STATE GRID PERFORMANCE:

Power point presentation on grid performance for the month of November & December 2017.

---- Members may please note.

ITEM No. 3. IMPORTANT GRID INCIDENTS:

1. On 06.12.17 at 09:09 hrs, at New Chanditala 400KV sub-stn, Bus Zone differential protection operated at 400KV MB#2 during diversion of 400KV jeerat ckt through bus-tie breaker. All feeders, transformers & reactors connected to that bus tripped. During tripping, MB#1 was under shut down for winter maintenance work.

--- WBSETCL representative may please deliberate.

2. On 15.12.17 at 06:02 hrs ,at Malda 132KV sub-stn total power failure due to snapping of Earth wire between PGCIL T/L no. 15-18.

--- WBSETCL representative may please deliberate.

ITEM No: 4. OPERATIONAL PLANNING.

- (a) **ANTICIPATED POWER SUPPLY POSITION FOR THE MONTH OF MARCH, APRIL & MAY 2018.**

[All concerned are requested to furnish anticipated demand and generation forecast for these months to SLDC]

- (b) **SETTLEMENT OF SHUT DOWN PROPOSALS FOR THE MONTH OF MARCH, APRIL & MAY 2018 i.r.o GENERATING UNITS, TRANSMISSION LINES AND OTHER EQUIPMENTS.**

[All concerned are requested to furnish their shut down proposals for these months to SLDC]

ITEM No: 5. ISSUES RAISED BY SLDC:

- A. As per Provisions of Clause no. 3.c of Miscellaneous Provisions Regulation 2013 published by Honorable WBERC the SLDC charge shall be payable by licensees quarterly in advance based on estimated energy to be transmitted by them through intra-state grid under long term access and medium term access. Estimation procedure for the same needed to be settled.
- B. Furnishing Generator Transformer Tap details by generating stations.
- C. Generating stations needed to furnish RGMO/FGMO details of the generators on monthly basis.
- D. Sharing of VAR loading by generators to maintain proper system voltage.

ITEM No: 6. AGENDA NOTE PUT UP BY SLCF MEMBERS FOR DISCUSSION:

6.1. Agenda note put up by BkTPP

- 1. In BkTPP –ARAMBAG Circuit, PLCC Channel -1 was not in service from 15.07.2017 due to problem at Arambag end. Panel at BkTPP end is healthy and kept off.
- 2. In BkTPP, there are eleven (11) nos. outgoing feeders for evacuation of power. Out of these, 220 kV/33 kV, 50 MVA PASS transformer bay has been commissioned and charged since 18.05.2015 for supplying power to the local 33 kV substation of WBSEDCL (Muthaberia) on temporary basis. Now one 220 kV/132 kV/33 kV substation has been commissioned at Sadaipur near to BkTPP since 20.04.2017. So, further assessment is required towards continuation of the said feeder from BkTPP. If it is necessary then, requested to incorporate the line CVTs in 220 kV side of the bay as BkTPP losing sent out value reasonably for taking voltage feedback from excessively loaded 220 kV Bus VT.

ITEM No: 7. Date and venue of next SLCF (i.e. 54th) Meeting.

ITEM No: 8. MISCELLANEOUS:

Memo No. SLDC/ How/ 109/ 2017-18/

Dated : 25/01/2018

Copy for information please:-

1. PS to Managing Director, WBSETCL, Vidyut Bhavan, Kolkata-91.
2. PS to Managing Director, DPL, Kolkata -107.
3. PS to Director (Operations), WBSETCL, Vidyut Bhavan, Kolkata-91.
4. PS to Director (RT), WBSEDCL, Vidyut Bhavan, Kolkata-91.
5. PS to Executive Director (OS), WBPDC, Salt Lake City, Kolkata-700 098.
6. C.E, SLDC, WBSETCL, Howrah-09.
7. C.E, Transmission-I, WBSETCL, Vidyut Bhavan, Kol-91.
8. C.E, Transmission-II, WBSETCL, Vidyut Bhavan, Kol-91.
9. C.E, CTD, WBSETCL, AbhiksanBhavan, Kol-91.
10. C.E, Communication, WBSETCL, AbhiksanBhavan, Kol-91.
11. Chief Engineer, CLD, DVC, Howrah.
12. C.E.(PTP) WBSEDCL, Vidyut Bhavan, Kolkata-91.
13. G.M , (SO) CESC Ltd., Statesman House, Kol- 01.
14. G.M. BTPS, WBPDC.
15. G.M. STPS, WBPDC.
16. G.M. KTPP, WBPDC.
17. G.M. BKTPP, WBPDC.
18. G.M. SGTPP, WBPDC.
19. Sri S. Namjoshi, Vice-President, Engineering & Projects, IPCL
20. Sri I. B. Chakraborty, Vice-President, Engineering & Projects, IPCL
21. Addl. Chief Engineer, SLDC, WBSETCL, Howrah-09.
22. Addl. Chief Engineer, ALDC, WBSEDCL.
23. Sri N.G.Saha, DGM, WBPDC.
24. Sri A. Sen Gupta, DGM, System Control Department, CESC Ltd, CESC House, Kol- 01.
25. Sri S. K. Sarkar, G.S.(T&D, Load Management), DPSC Ltd.
26. Sri R. Biswas, Sr. Manager, ALDC, DPL.
27. Sri Suhas Ch. Ray Sr.Manager(Operation), KTPP WBPDC,
28. Sri Indrajit Banerjee Manager(Operation), KTPP WBPDC.
29. Sri D. Chanda, Sr.Manager(PS), BKTPP, WBPDC.
30. Mr. Joynal Abedin, Sr.Manager(E.O.), BKTPP, WBPDC.
31. Sri K. Banerjee, Manager, System Control Department, CESC Ltd, CESC House, Kol- 01.
32. Sri A.Biswas, Manager(PS), BKTPP, WBPDC.
33. Sri F.Hossain, Manager (PS), SGTPP, WBPDC.
34. Sri M.S.Bapari, Manager (PS), SGTPP, WBPDC.
35. Sri M. Mallik, Sr. Manager, (System Operation – Electrical), BTPS, WBPDC.
36. Sri S. Maiti, Sr. Manager (O), STPS, WBPDC.