

STATE LOAD DESPATCH CENTER

AGENDA FOR 54th MEETING Of State Level Co-ordination Forum

Date: 18/04/2018

Venue:SLDC

ITEM No:1. CONFIRMATION OF THE MINUTES OF 53rd SLCF MEETING HELD ON 30.01.2018.

The minutes was circulated vide memo no: **SLDC/How/109/2017-18/1628** dated 16/02/2018 and the same was also published in the website(www.wbslde.in).

---- Members may please discuss.

ITEM No: 2. REVIEW OF STATE GRID PERFORMANCE:

Power point presentation on grid performance for the month of January-18, February-18 and March-18.

---- Members may please note.

ITEM No. 3. IMPORTANT GRID INCIDENTS:

1. CESC got islanded on 13.03.2018.

--- CESC representative may please deliberate.

2. 132 KV Bus fault occurred at 220 KV Midnapur Sub-stn. at 06.25 hrs on 15.03.2018.

--- WBSETCL representative may please deliberate.

3. 132 KV Bus fault occurred at 132 KV Liluah Sub-stn. at 17.05 hrs. on 03.03.2018.

--- WBSETCL representative may please deliberate.

4. Total power failure at Amtala, Najirpur, Domkal at 19.34 hrs on 04/04/18.

--- WBSETCL representative may please deliberate.

ITEM No: 4. OPERATIONAL PLANNING.

- (a) **ANTICIPATED POWER SUPPLY POSITION FOR THE MONTH OF MAY, JUNE & JULY 2018.**

[All concerned are requested to furnish anticipated demand and generation forecast for these months to SLDC]

(b) SETTLEMENT OF SHUT DOWN PROPOSALS FOR THE MONTH OF MAY, JUNE & JULY 2018 i.r.o GENERATING UNITS, TRANSMISSION LINES AND OTHER EQUIPMENTS.

[All concerned are requested to furnish their shut down proposals for these months to SLDC]

ITEM No: 5. ISSUES RAISED BY SLDC:

- A. Unit back down of BkTPP Unit #1 due to low system demand.
- B. Uploading of Event Logger/DR recorder in ERPC PDMS server by CTD in case of WBSETCL S/S and by Power Plants in case of WBPDCCL plants.
- C. Injection of reactive power by units at low voltage / absorption during high voltage.

ITEM No: 6. AGENDA NOTE PUT UP BY SLCF MEMBERS FOR DISCUSSION:

6.1. Agenda note put up by BkTPP

- A. It was observed on 02.04.2018 that unit 5 was desynchronized at 00:17 hrs dated 02.04.18 due to low system demand and synchronized at 11:18 hrs dated 02.04.18. It is very harmful for unit health.
So it is requested to schedule shut down for a longer period of time as unit back down as and when required.
- B. During shut down process of a unit due to low system demand 95% rule of ABT system does not allow us to shutdown of unit early even we are capable .
So it will be better to ignore 95 % rule of ABT system during shut down process of a unit due to low system demand.
- C. Most of the time SLDC website is not available.
- D. In the 53rd SLCF meeting held on 31.01.2018, WBPDCCL informed that the 220kV/33kV, 50MVA PASS Transformer bay is no more necessary since 220kV/132/33 KV Sadaipur Substation is commissioned successfully from April 2017. If that bay is necessary, then 220kV side separate CVT may be installed as BKTPP is losing sent out value reasonably due to the PT voltage taken from 220KV Main Bus #1 VT. Regarding this one letter was issued but still no response was received from SLDC.

6.2. Agenda note put up by KTPS

- A. Up-gradation of APEX meter i.r.o KTPS.

ITEM No: 7. Date and venue of next SLCF (i.e. 55th) Meeting.

ITEM No: 8. MISCELLANEOUS:

Copy for kind information please:-

1. PS to Managing Director, WBSETCL, VidyutBhavan, Kolkata-91.
2. PS to Managing Director, DPL, Kolkata -107.
3. PS to Director (Operations), WBSETCL, Vidyut Bhavan,Kolkata-91.
4. PS to Director (RT), WBSEDCL, VidyutBhavan, Kolkata-91.
5. PS to Executive Director (OS), WBPDC, Salt Lake City, Kolkata-700 098.
6. C.E, SLDC, WBSETCL, Howrah-09.
7. C.E, Transmission-I, WBSETCL, VidyutBhavan, Kol-91.
8. C.E, Transmission-II, WBSETCL, VidyutBhavan, Kol-91.
9. C.E, CTD, WBSETCL, AbhiksanBhavan, Kol-91.
10. C.E, Communication, WBSETCL, AbhiksanBhavan, Kol-91.
11. Chief Engineer, CLD, DVC, Howrah.
12. C.E.(PTP) WBSEDCL, Vidyut Bhavan, Kolkata-91.
13. G.M , (SO) CESC Ltd., Statesman House, Kol- 01.
14. G.M. BTPS, WBPDC.
15. G.M. STPS, WBPDC.
16. G.M. KTPP, WBPDC.
17. G.M. BKTPP, WBPDC.
18. G.M. SGTPP, WBPDC.
19. Sri I. B. Chakraborty, Vice-President, Engineering & Projects, IPCL
20. Addl. Chief Engineer, SLDC,WBSETCL, Howrah-09.
21. Addl. Chief Engineer, ALDC,WBSEDCL.
22. Sri N.G.Saha, DGM, WBPDC.
23. Sri A. Sen Gupta, DGM, System Control Department, CESC Ltd, CESC House, Kol- 01.
24. Sri S. K. Sarkar, G.S.(T&D, Load Management), DPSC Ltd.
25. Sri R. Biswas, Sr. Manager, ALDC, DPL.
26. Sri Suhas Ch. Ray Sr.Manager(Operation), KTPP WBPDC,
27. Sri Indrajit Banerjee Manager(Operation), KTPP WBPDC.
28. Sri D. Chanda,Sr.Manager(PS), BKTPP, WBPDC.
29. Mr. Joynal Abedin, Sr.Manager(E.O.), BKTPP, WBPDC.
30. Sri K. Banerjee, Manager, System Control Department, CESC Ltd, CESC House, Kol- 01.
31. Sri A.Biswas, Manager(PS),BKTPP,WBPDC.
32. Sri F.Hossain, Manager (PS), SGTPP, WBPDC.
33. Sri M.S.Bapari,Manager (PS), SGTPP, WBPDC.
34. Sri M. Mallik, Sr. Manager, (System Operation – Electrical), BTPS, WBPDC.
35. Sri S. Maiti, Sr. Manager (O), STPS, WBPDC.