

Import TTC/ATC of WBSETCL at STU (W.B)-CTU boundary for, JULY'2022 (peak)

1. Base Cases considered :

- a. WBSEDCL own system : 7325 MW.
- b. CESC system : 2120 MW. (Synchronized at Kasba)
- c. IPCL Drawal : 125 MW
- d. West Bengal total demand : 9570 MW [=a+b+c]
(Load P.f : 0.95)

2. Total Available Generation (S/O) in West Bengal (in MW) :

- i. WBPDCCL own Generation (in Avg. MW) 3700 + 260
(KTPP :700, BKTPP :950, SGTPP : 1360, STPS :460, BTPS :230,DPL:260)
- ii. PPSP (3 units) : 675
- iv. HEL (2unit) : 540
- v. WBSEDCL Hydel : 60
- vi. TLDP III +TLDP IV : 280
- vii. CESC : 830
- viii. HIREL : 130
- viii. IPP/PPP(TPH+CPL+BEL+PCBL) : 165

ix. Total Available Generation (S/O) in W.B= **6640 MW**

3. Requirement from outside for W.B. = (9570-6640) MW = 2930 MW (Excluding loss).

4. Now, working out with the above Load-Generation scenario,

Under normal condition with availability of all circuits and availability of load & generation as above (under 1. & 2.), Net drawal i.e. summation of all W.B tie flows (at STU-CTU boundary) comes as **3441 MW** (including loss).

At above Load-Gen scenario :

Import TTC of WBSETCL at STU & CTU boundary (CTU to STU):

5852 MW

Constraints or violation arrived under (N-1) condition: Tripping of 400 KV Jeerat-Subhasgramckt (400 KV tie-lines have been considered for (N-1) condition)

1. 220KV Jeerat-Barasat d/c= 219.3 MW (610 Amps)

TRM (Transfer Reliability Margin) (Considering average S/O of the largest Gen Unit) : 450 MW.

ATC of WBSETCL at STU & CTU boundary (CTU to STU) : TTC-TRM= (5852-450) MW = **: 5402 MW**



9/3/22

Additional Chief Engineer
STATE LOAD DESPATCH CENTRE
WBSETCL, HOWRAH

