



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/ 131

Dated : 10/5/24.

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of April 2024.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **April 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

10/5/24

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbslde_power@yahoo.co.in, wbslde.enac@gmail.com, Web-site : www.wbslde.in



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/

Dated :

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of April 2024.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **April 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-06/2024-25/ 131 (1-8)

Dated: 10/5/24.

Copy for kind information to:

1. The Managing Director, WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan
8. The Joint Director (Engg), WBERC, FD- 415A, Poura Bhavan, Sector – III, Kolkata – 700106.

Encl.: 01 Page.

Rly 10/5/24

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025

WBDCL POWER STATIONS

April 2024

HIGH DEMAND SEASON

Item	BKTPP		BTPS_STAGE_I		BTPS_STAGE_II		DPL_STAGE_1		DPL_STAGE_2		KTPP		SGTPP_STAGE_1		SGTPP_STAGE_II		STPS	
	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK
No. of blocks during the period	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400
Installed Capacity (IC) (MW)	1050.00	1050.00	60.00	60.00	215.00	215.00	300.00	300.00	250.00	250.00	840.00	840.00	600.00	600.00	1000.00	1000.00	500.00	500.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00	10.40	10.40	9.00	9.00	8.50	8.50	9.00	9.00	9.60	9.60	9.00	9.00	9.00	9.00	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	117.072515	580.298674	5.711500	24.818051	23.628828	116.752072	23.949000	117.887283	27.056750	135.073835	78.908095	374.513722	63.940000	318.692074	100.209779	494.149921	53.823423	260.625787
Plant Load Factor (PLF):	102.10	101.22	88.53	76.94	100.64	99.46	72.70	71.58	99.11	98.96	86.59	82.20	97.59	97.28	91.77	90.50	98.58	95.47

DATE : 09-05-2024


 10/05/24
 Divisional Engineer / Superintendent Engineer
 SLDC, WBSETCL