



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

**Office of the Chief Engineer**  
**State Load Despatch Centre**

**WBSETCL**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbslde.in](http://www.wbslde.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.

E-Mail: CE : [ce.wbslde@gmail.com](mailto:ce.wbslde@gmail.com)/  
[ce.wbslde@wbsetcl.in](mailto:ce.wbslde@wbsetcl.in)

Control Room: [wbslde@gmail.com](mailto:wbslde@gmail.com)

Energy Account: [wbslde.enac@gmail.com](mailto:wbslde.enac@gmail.com)

Memo No : SLDC/HOW/B-31/2024-25/ 1070

Dated : 5/3/25.

To  
The Vice President (Commercial),  
Hiranmaye Energy Limited,  
Plot No. X -1, 2 & 3, Block-EP,  
Sector -V, Saltlake, Kolkata -700091.

**Sub: Plant Load Factor for the month of February 2025 i.r.o. Hiranmaye Energy Limited.**


Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **February 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.

  
Chief Engineer, SLDC(WB)

**WBSETCL**

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091

CIN No. U40101WB2007SGC113474, Website: [www.wbsetcl.in](http://www.wbsetcl.in)



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

**Office of the Chief Engineer**  
**State Load Despatch Centre**

**WBSETCL**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbsldc.in](http://www.wbsldc.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.  
E-Mail: CE : [ce.wbsldc@gmail.com](mailto:ce.wbsldc@gmail.com)/  
[ce.wbsldc@wbsetcl.in](mailto:ce.wbsldc@wbsetcl.in)  
Control Room: [wbsldc@gmail.com](mailto:wbsldc@gmail.com)  
Energy Account: [wbsldc.enac@gmail.com](mailto:wbsldc.enac@gmail.com)

Memo No : SLDC/HOW/B-31/2024-25/

Dated :

To  
The Vice President (Commercial),  
Hiranmaye Energy Limited,  
Plot No. X -1, 2 & 3, Block-EP,  
Sector -V, Saltlake, Kolkata -700091.

**Sub: Plant Load Factor for the month of February 2025 i.r.o. Hiranmaye Energy Limited.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **February 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 (One) Page.

Sd/-  
( R.Chakraborty )  
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-25/2024-25/ 1070 (1-1)  
Copy for kind information to:

Dated: 5/3/25.

1. The Director (Operations), WBSETCL, 8<sup>th</sup> Floor, Vidyut Bhavan, Kolkata – 700 091.
2. The Director (RT), WBSEDCL, 7<sup>th</sup> Floor, Vidyut Bhavan, Kolkata – 700 091.
3. The C.E (PTP), WBSEDCL, 7<sup>th</sup> floor Vidyut Bhavan, B-Block, Sector -II, Kolkata-91.
4. The Joint Director (Eng). WBERC, Plot No: AH/5(2<sup>nd</sup> and 4<sup>th</sup> Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.

Encl : 01 (One) Page.

*RCM 5/3/25*  
Chief Engineer, SLDC(WB)

**WBSETCL**

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091  
CIN No. U40101WB2007SGC113474, Website: [www.wbsetcl.in](http://www.wbsetcl.in)

STATE LOAD DISPATCH CENTRE  
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED  
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025


STATION: HIRANMAYE ENERGY LIMITED

February 2025

LOW DEMAND SEASON

Item	HIREL	
	PEAK ( 17:00 to 21:00 hrs)	OFF PEAK ( 00:00 to 17:00 and 21:00 to 24:00 hrs)
Peak / Off Peak Hours		
No. of blocks during the period	448	2240
Installed Capacity (IC) (MW)	300.00	300.00
Normative Auxiliary Consumption in percentage (AUX):	10.50	10.50
Scheduled Generation in MU (Summation of No. of blocks during the period)	23.404000	116.654642
Plant Load Factor (PLF):	77.83	77.58

DATE : 03-03-2025

  
Superintending Engineer  
SLDC, WBSETCL