



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbslde.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah – 711109.

E-Mail: CE : ce.wbslde@gmail.com/
ce.wbslde@wbsetcl.in

Control Room: wbslde@gmail.com

Energy Account: wbslde.enac@gmail.com

Memo No: SLDC/HOW/B-29/2025-26/ 254

Dated : 9/6/25.

To
The Managing Director (Generation),
CESC Limited, CESC House,
Chowringhee Square, Kolkata-700 001.

**Sub: Plant Load Factor (PLF) for the month of May 2025 i.r.o. embedded
Generating Stations of CESC Ltd.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for embedded Generating Stations of CESC Ltd. under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

RDY 9/6/25

Encl: 01(one) Page

Chief Engineer, SLDC (WB).

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbslde.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah – 711109.
E-Mail: CE : ce.wbslde@gmail.com/
ce.wbslde@wbsetcl.in
Control Room: wbslde@gmail.com
Energy Account: wbslde.enac@gmail.com

Memo No: SLDC/HOW/B-29/2025-26/

Dated :

To
The Managing Director (Generation),
CESC Limited, CESC House,
Chowringhee Square, Kolkata-700 001.

Sub: Plant Load Factor (PLF) for the month of May 2025 i.r.o. embedded
Generating Stations of CESC Ltd.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for embedded Generating Stations of CESC Ltd. under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-09/2025-26/ 251 (1-6)
Copy for kind information to :

Dated : 9/6/25

1. The Joint Director (Engg), WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.
2. The Director (Opn), WBSETCL, 8th floor, Vidyut Bhavan, Kolkata-700091.
3. The VP (S/O), CESC House, Annex Building, Chowringhee Square, Kolkata - 700001.
4. The GM(S/O), CESC House, Annex Building, Chowringhee Square, Kolkata – 700001.
5. The VP, Budge Budge Generating Station, Pujali, Kolkata-700138.
6. The DGM, Southern Generating Station, 28, Garden Reach Road, Kolkata-700024.

Encl: 01(one) Page

RCM 9/6/25

Chief Engineer, SLDC (WB).

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in

**STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)**

Plant Load Factor (PLF) of the generating station

Financial Year :2025-2026


STATION: BUDGE BUDGE AND SOUTHERN(CESC)

May 2025

HIGH DEMAND SEASON

Item	BUDGE BUDGE		SOUTHERN	
	PEAK (00:00 to 02:00 and 22:00 to 24:00 hrs)	OFF PEAK (02:00 to 22:00 hrs)	PEAK (00:00 to 02:00 and 22:00 to 24:00 hrs)	OFF PEAK (02:00 to 22:00 hrs)
Peak / Off Peak Hours				
No. of blocks during the period	496	2480	496	2480
Installed Capacity (IC) (MW)	750.00	750.00	135.00	135.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	81.943250	349.413250	7.058750	26.739250
Plant Load Factor (PLF):	96.83	82.57	46.34	35.11

DATE : 04-06-2025


05/06/25
Superintending Engineer

SLDC,WBSETCL