



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbsldc.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah - 711109.

E-Mail: CE : ce.wbsldc@gmail.com/
ce.wbsldc@wbsetcl.in

Control Room: wbsldc@gmail.com
Energy Account: wbsldc.enac@gmail.com

Memo No : SLDC/HOW/B-31/2025-26/ 248

Dated : 5/6/25.

To
The Vice President (Commercial),
Hiranmaye Energy Limited,
Plot No. X -1, 2 & 3, Block-EP,
Sector -V, Saltlake, Kolkata -700091.

Sub: Plant Load Factor for the month of May 2025 i.r.o. Hiranmaye Energy Limited.


Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.


Chief Engineer, SLDC(WB)

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbslde.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah – 711109.
E-Mail: CE : ce.wbslde@gmail.com/
ce.wbslde@wbsetcl.in
Control Room: wbslde@gmail.com
Energy Account: wbslde.enac@gmail.com

Memo No : SLDC/HOW/B-31/2025-26/

Dated :

To
The Vice President (Commercial),
Hiranmaye Energy Limited,
Plot No. X -1, 2 & 3, Block-EP,
Sector -V, Saltlake, Kolkata -700091.

Sub: Plant Load Factor for the month of May 2025 i.r.o. Hiranmaye Energy Limited.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 (One) Page.

Sd/-
(R.Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-25/2025-26/ 248(1-4)
Copy for kind information to:

Dated: 5/6/25

1. The Director (Operations), WBSETCL, 8th Floor, Vidyut Bhavan, Kolkata – 700 091.
2. The Director (RT), WBSEDCL, 7th Floor, Vidyut Bhavan, Kolkata – 700 091.
3. The C.E (PTP), WBSEDCL, 7th floor Vidyut Bhavan, B-Block, Sector –II, Kolkata-91.
4. The Joint Director (Eng). WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111
Action Area -1 A, New Town, Kolkata-700163.

Encl : 01 (One) Page.


Chief Engineer, SLDC(WB)

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2025-2026


STATION: HIRANMAYE ENERGY LIMITED

May 2025

HIGH DEMAND SEASON

Item	HIREL	
	PEAK (00:00 to 02:00 and 22:00 to 24:00 hrs)	OFF PEAK (02:00 to 22:00 hrs)
Peak / Off Peak Hours		
No. of blocks during the period	496	2480
Installed Capacity (IC) (MW)	300.00	300.00
Normative Auxiliary Consumption in percentage (AUX):	10.50	10.50
Scheduled Generation in MU (Summation of No. of blocks during the period)	15.397366	67.061314
Plant Load Factor (PLF):	46.25	40.28

DATE : 04-06-2025


Superintending Engineer

SLDC, WBSETCL