



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

**Office of the Chief Engineer**  
**State Load Despatch Centre**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbsldc.in](http://www.wbsldc.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.  
E-Mail: CE : [ce.wbsldc@gmail.com](mailto:ce.wbsldc@gmail.com)/  
[ce.wbsldc@wbsetcl.in](mailto:ce.wbsldc@wbsetcl.in)  
Control Room: [wbsldc@gmail.com](mailto:wbsldc@gmail.com)  
Energy Account: [wbsldc.enac@gmail.com](mailto:wbsldc.enac@gmail.com)

**Memo No: SLDC /How /B-23/2025-26/ 310(1-10)**

**Date: 21/6/25.**

To

1. The G M (System Operation),CESCLimited,CESC House,Annex Building, Chowringhee Square, Kolkata – 700 001.
2. The Chief Engineer(Commercial), WBSEDCL, Vidyut Bhavan, Sector-II, Bidhannagar, Kol – 91.
3. The Chief Engineer,(PTP),WBSEDCL,7<sup>th</sup> floor Vidyut Bhavan,B-Block, Sector-II, Bidhannagar, Kolkata – 700 091.
4. The Addl. Chief Engineer, ALDC, WBSEDCL,M-3 Substation,J.C.Block Salt Lake,Sector -3, Kolkata – 700 098.
5. The AGM(F&A), SLDC, WBSETCL, Danesh Sk. Lane, Howrah – 711 109.
6. The Vice President, Budget & Regulatory Affairs, IPCL(formerly DPSC Limited),Head Office, Plot No. X- 1, 2&3, Block-EP, Sector-V,Salt Lake City, Kolkata – 700091.
7. The Assistant General Manager, Dalmia Cement Bharat Ltd., Sangam garden, Saraswati Block ,Tantigeria, PO:Vidyasagar University, P.S: Midnapore Kotwali, Dist-West Midnapore-721102.
8. The Branch Manager,M/S ITC Ltd., 93/1, Karl Marx Sarani,Kidderpore Kolkata-700043.
9. The Manager, ITC Ltd.,India Tobacco Division, Virginia House, J.L.Nehru Road, Kol-700071.
10. The GM, ITC Royal Bengal & ITC Sonar, Kolkata-700046.

**Sub: Provisional Statement of Reactive Energy (VARH) Charges for the period from 19.05.2025 to 25.05.2025 (Week 08) as per Suo-moto order dated 21.07.2016 of the Hon'ble WBERC in the matter of case no: SM-14/16-17.**

Sir,

The Statement of provisional Reactive Energy charges with payables / receivables particulars for the above mentioned period along with detailed statement for proportion of usage at STU-CTU boundary is enclosed. The constituents, who have to pay the Reactive Energy charges as indicated in the statement, are requested to make payment to the “SLDC-DS-FUND-WBSETCL” account operated by SLDC(WB),WBSETCL within 07 days of the billing date as per **Suo-moto order dated 21.07.2016 of the Hon'ble WBERC in the matter of case no: SM-14/16-17.** In case of delayed payment for Reactive Energy charges against these bills beyond 07 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay. Observations, if any, may be intimated to the Chief Engineer, SLDC (WB) within a fortnight.

Yours faithfully,

Encl:As above.

  
24.06.25  
Chief Engineer, SLDC.

**WBSETCL**

**Registered Office:** Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091  
**CIN No.** U40101WB2007SGC113474, **Website:** [www.wbsetcl.in](http://www.wbsetcl.in)



**WBSETCL**

West Bengal State Electricity Transmission Company Limited  
( A Govt.of W.B. Enterprise)  
Office of the chief engineer  
State Load Despatch Center (W.B),  
PO: Danesh SK. Lane, Howrah-711 109.

**Provisional Reactive Energy (VARH) Charge Statement**

For the period: 19-05-2025 To 25-05-2025

Of the year: 2025-2026

(All figures are in Rupees)

Utilities Receivable by them		Utilities Payable by them	
Regional Reactive Pool	192632	WBSEDCL	141397
		IPCL	7229
		CESC	43928
		ITC VIRGINIA	16
		ITC HOTELS	62
		ITC KHIDDERPORE	0
		DALMIA CEMENT	0
Total	192632	Total	192632

N.B:

- i) Reactive Charge calculation is done as per Suo-moto order dated 21.07.2016 of the Hon'ble WBERC in the matter of case no: SM-14/16-17.

SE, WBSLDC





**WBSETCL**

West Bengal State Electricity Transmission Company Limited  
( A Govt. of W.B. Enterprise )  
Office of the chief engineer  
State Load Despatch Center (W.B),  
PO: Danesh SK. Lane, Howrah-711 109.

**Detailed Statement for proportion of usage at STU-CTU boundary**

**For the period: 19-05-2025 To 25-05-2025**

Date	WBSEDCL	IPCL	CESC	ITC VIRGINIA	ITC HOTELS	ITC KHIDDERPORE	DALMIA CEMENT
19/05/2025	78.814	4.048	26.045	0.010	0.037	0.000	0.000
20/05/2025	94.121	3.986	27.998	0.011	0.037	0.000	0.000
21/05/2025	89.352	4.201	29.299	0.011	0.037	0.000	0.000
22/05/2025	83.657	4.482	26.992	0.011	0.037	0.000	0.000
23/05/2025	87.315	4.731	26.134	0.011	0.037	0.000	0.000
24/05/2025	82.247	4.744	26.273	0.009	0.037	0.000	0.000
25/05/2025	81.101	4.313	22.608	0.007	0.037	0.000	0.000
<b>Total Usage for Week</b>	596.607	30.503	185.349	0.069	0.260	0.000	0.000
<b>Proportionate Usage for Week in %</b>	73.40%	3.75%	22.80%	0.01%	0.03%	0.00%	0.00%
<b>Amount receivable by Regional Reactive Pool in Rs.</b>	192632						
<b>Proportionate amount payable by utilities in Rs. for the week</b>	141397	7229	43928	16	62	0	0

N.B:

Following is the methodologies for calculation of proportion usage in CTU-STU boundary:

1. WBSEDCL usage : ((IMPORT SCHEDULE + EXPORT SCHEDULE + ISGS SCHEDULE + URS SCHEDULE ) at CTU-STU boundary + (SGTPP SCHEDULE - (ACTUAL ENERGY FLOW THROUGH 400 KV SgTPP-GOKARNA D/C, 220 KV SgTPP-N.SAGARDIGHI D/C AND 400 KV SgTPP-JEERAT D/C)))
2. CESC usage: (IMPORT SCHEDULE + EXPORT SCHEDULE) at CTU-STU boundary + HEL SCHEDULE at SUBHASGRAM(PG) boundary
3. IPCL usage: (IMPORT SCHEDULE + EXPORT SCHEDULE) at CTU-STU boundary
4. Dalmia usage: IMPORT SCHEDULE at CTU-STU boundary
5. ITC-Khdpr usage: IMPORT SCHEDULE at CTU-STU boundary
6. ITC-Virginia usage: IMPORT SCHEDULE at CTU-STU boundary
7. ITC-Hotels usage: IMPORT SCHEDULE at CTU-STU boundary



SE, WBSLDC

19-05-2025 To 25-05-2025

25-05-2025

19-05-2025