

State Load Despatch Centre
Import of West Bengal Transfer Capability for FEBRUARY, 2024

Issue Date: 13.12.2023

Issue Time: 1200 hrs

Revision No. 00

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2024 to 29th February 2024	00-12 hrs	7437	450	6987				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 7429 MW Gen 5705 MW
1st February 2024 to 29th February 2024	12- 16 hrs	7437	450	6987				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 7429 MW Gen 5705 MW
1st February 2024 to 29th February 2024	16-00 hrs	7437	450	6987				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 7429 MW Gen 5705 MW
Limiting Constraints								

1) Tripping of 400 KV JRT-SGRM ckt & 400KV GOKARNA-N, PURNEA creating constraints in -400 KV JEEERAT 315 MVA 400/220 KV ICTs (316 MVA), for WBSEDCL, as well as CESC peak case.
 2) As per LGBR there is no constraints for Export in FEBRUARY 2024.

[Signature]

Additional Chief Engineer
 SLDC, WBSETCL
 Additional Chief Engineer
 STATE LOAD DESPATCH CENTRE
 WBSETCL, HOWRAH