

State Load Despatch Centre
Import of West Bengal Transfer Capability for JANUARY,2024

Issue Date: 13.10.2023

Issue Time: 1200 hrs

Revision No. 00

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2024 to 31st January 2024	00-12 hrs	7421	450	6971				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10768 MW Gen 5773
1st January 2024 to 31st January 2024	12- 16 hrs	7421	450	6971				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10768 MW Gen 5773 MW
1st January 2024 to 31st January 2024	16-00 hrs	7421	450	6971				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10768 MW Gen 5773
Limiting Constraints		1) Tripping of 400 kV JEERAT-S'GRM ckt creating constraints in-400 KV JEERAT 315 MVA 400/220 KV ICTs (316 MVA), for WBSEDCL as well as CESC peak case. 2) As per LGBR there is no constraints for Export in JANUARY'2024.						


 Additional Chief Engineer
 SLD, WBSETCL