

**State Load Despatch Centre**  
**Import of West Bengal Transfer Capability for MARCH,2024**

Issue Date: 13.12.2023

Issue Time: 1200 hrs

Revision No. 00

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st MARCH 2024 to 31st MARCH 2024	00-12 hrs	7391	450	6941				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10171 MW Gen 6545
1st MARCH 2024 to 31st MARCH 2024	12- 16 hrs	7391	450	6941				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10171 MW Gen 6545 MW
1st MARCH 2024 to 31st MARCH 2024	16-00 hrs	7391	450	6941				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10171 MW Gen 6545
<b>Limiting Constraints</b>		1) Tripping of 400 KV JEERAT-SGRM & 400KV GOKARNA-N.PURNEA ckt creating constraints in-400 KV JEERAT 315 MVA 400/220 KV ICTS (318 MVA), for WBSEDCL as well as CESC peak case. 2) As per LGBR there is no constraints for Export in MARCH2024.						



**Additional Chief Engineer**

SLDC,WBSETCL

*Additional Chief Engineer*

STATE LOAD DESPATCH CENTRE

WBSETCL, HOWRAH