



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-30/2024-25/ 236

Dated : 11/6/24.

To
The G M, HEL,
Baneswarchak, Gopalchak,
Haldia - 721658.

Sub: Plant Load Factor (PLF) for the month of May 2024 i.r.o. HEL.


Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.


Chief Engineer, SLDC(WB).

WBSETCL



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-30/2024-25/

Dated :

To
The G M, HEL,
Baneswarchak, Gopalchak,
Haldia - 721658.

Sub: **Plant Load Factor (PLF) for the month of May 2024 i.r.o. HEL.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC(WB).

Memo No : SLDC/HOW/B-20/2024-25/ 236 (1-2)
Copy for kind information to:

Dated : 11/6/24.

1. The G M (S/O), CESC House, Annex Building, Chowringee Square, Kolkata - 700001
2. The Joint Director (Eng). WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.

Encl : 01 (One) Page.


Chief Engineer, SLDC(WB).

WBSETCL

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025

STATION: HALDIA ENERGY LIMITED

May 2024

HIGH DEMAND SEASON

Item	HEL	
	SGS PEAK	SGS OFF PEAK
No. of blocks during the period	496	2480
Installed Capacity (IC) (MW)	600.00	600.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	59.200374	273.082122
Plant Load Factor (PLF):	87.44	80.67

DATE : 11-06-2024


11/06/24
Divisional Engineer / Superintendent Engineer
SLDC, WBSETCL