



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No : SLDC/HOW/B-31/2024-25/ 128

Dated : 7/8/24

To
The Vice President (Commercial),
Hiranmaye Energy Limited,
Plot No. X -1, 2 & 3, Block-EP,
Sector –V, Saltlake, Kolkata -700091.

Sub: Plant Load Factor for the month of July 2024 i.r.o. Hiranmaye Energy Limited.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **July 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

[Handwritten Signature] 7/8/24

Encl : 01 (One) Page.

Chief Engineer, SLDC(WB).

WBSETCL



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No : SLDC/HOW/B-31/2024-25/

Dated :

To
The Vice President (Commercial),
Hiranmaye Energy Limited,
Plot No. X -1, 2 & 3, Block-EP,
Sector -V, Saltlake, Kolkata -700091.

Sub: Plant Load Factor for the month of July 2024 i.r.o. Hiranmaye Energy Limited.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **July 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 (One) Page.

Sd/-
(R.Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-25/2024-25/ 428 (1-4)

Dated: 7/8/24

Copy for kind information to:

1. The Director (Operations), WBSETCL, 8th Floor, Vidyut Bhavan, Kolkata – 700 091.
2. The Director (RT), WBSEDCL, 7th Floor, Vidyut Bhavan, Kolkata – 700 091.
3. The C.E (PTP), WBSEDCL, 7th floor Vidyut Bhavan, B-Block, Sector -II, Kolkata-91.
4. The Joint Director (Eng). WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.

Encl : 01 (One) Page.

RCh
7/8/24

Chief Engineer, SLDC(WB).

WBSETCL

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025

STATION: HIRANMAYE ENERGY LIMITED

July 2024

LOW DEMAND SEASON

Item	HIREL	
	SGS PEAK	SGS OFF PEAK
No. of blocks during the period	496	2480
Installed Capacity (IC) (MW)	300.00	300.00
Normative Auxiliary Consumption in percentage (AUX):	10.50	10.50
Scheduled Generation in MU (Summation of No. of blocks during the period)	22.345000	110.298675
Plant Load Factor (PLF):	67.11	66.26

DATE : 05-08-2024

Handwritten signature
07/08/24
Superintendent Engineer

SLDC, WBSETCL