



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/ 431

Dated : 7/8/24.

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of July 2024.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **July 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

RM 7/8/24

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/

Dated :

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of July 2024.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **July 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-06/2024-25/ 431 (1-8)

Dated: 7/8/24

Copy for kind information to:

1. The Managing Director, WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan
8. The Joint Director (Engg), WBERC, FD- 415A, Poura Bhavan, Sector – III, Kolkata – 700106.

Encl.: 01 Page.

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbslde_power@yahoo.co.in, wbslde.enac@gmail.com, Web-site : www.wbslde.in

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
 (A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025

WBPDC POWER STATIONS

July 2024

LOW DEMAND SEASON

Item	BKTPP		BTPS_STAGE_I		BTPS_STAGE_II		DPL_STAGE_I		DPL_STAGE_2		KTPP		SGTTP_STAGE_I		SGTTP_STAGE_II		STPS	
	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK
No. of blocks during the period	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480
Installed Capacity (IC) (MW)	1050.00	1050.00	60.00	60.00	215.00	215.00	300.00	300.00	250.00	250.00	840.00	840.00	600.00	600.00	1000.00	1000.00	500.00	500.00
Normative Auxiliary Consumption in percentage (AUX);	9.00	9.00	10.40	10.40	9.00	9.00	8.50	8.50	9.00	9.00	9.60	9.60	9.00	9.00	9.00	9.00	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	96.312500	476.599354	6.661500	28.666504	23.844750	116.838397	20.901250	105.197140	27.282500	132.351561	65.788750	317.101279	66.877500	332.200064	117.800000	583.973127	57.209000	276.241387
Plant Load Factor (PLF);	81.29	80.45	99.93	86.01	98.29	96.32	61.41	61.81	96.71	93.83	69.87	67.35	98.78	98.13	104.40	105.50	101.40	97.92

DATE : 05-08-2024

Handwritten Signature
 Superintendent Engineer

SLDC, WBSETCL