



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbslde.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah – 711109.
E-Mail: CE : ce.wbslde@gmail.com/
ce.wbslde@wbsetcl.in
Control Room: wbslde@gmail.com
Energy Account: wbslde.enac@gmail.com

Memo No: SLDC/HOW/B-29/2024-25/700

Dated : 12/11/24 .

To
The Managing Director (Generation),
CESC Limited, CESC House,
Chowringhee Square, Kolkata-700 001.

**Sub: Plant Load Factor (PLF) for the month of October 2024 i.r.o. embedded
Generating Stations of CESC Ltd.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for embedded Generating Stations of CESC Ltd. under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **October 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01(one) Page

POY 12/11/24

Chief Engineer, SLDC (WB).

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbsetcl.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah – 711109.
E-Mail: CE : ce.wbsetcl@gmail.com/
ce.wbsetcl@wbsetcl.in
Control Room: wbsldc@gmail.com
Energy Account: wbsldc.enac@gmail.com

Memo No: SLDC/HOW/B-29/2024-25/

Dated :

To
The Managing Director (Generation),
CESC Limited, CESC House,
Chowringhee Square, Kolkata-700 001.

Sub: Plant Load Factor (PLF) for the month of October 2024 i.r.o. embedded
Generating Stations of CESC Ltd.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for embedded Generating Stations of CESC Ltd. under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **October 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-09/2024-25/ 700(1-6)
Copy for kind information to :

Dated : 12/11/24.

1. The Joint Director (Engg), WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.
2. The Director (Opn), WBSETCL, 8th floor, Vidyut Bhawan, Kolkata-700091.
3. The VP (S/O), CESC House, Annex Building, Chowringhee Square, Kolkata - 700001.
4. The GM(S/O), CESC House, Annex Building, Chowringhee Square, Kolkata – 700001.
5. The VP, Budge Budge Generating Station, Pujali, Kolkata-700138.
6. The DGM, Southern Generating Station, 28, Garden Reach Road, Kolkata-700024.

Encl: 01(one) Page


Chief Engineer, SLDC (WB).

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year :2024-2025


STATION: BUDGE BUDGE AND SOUTHERN(CESC)

October 2024

LOW DEMAND SEASON

Item	BUDGE BUDGE		SOUTHERN	
	PEAK (18:00 to 22:00 hrs)	OFF PEAK (00:00 to 18:00 and 22:00 to 24:00 hrs)	PEAK (18:00 to 22:00 hrs)	OFF PEAK (00:00 to 18:00 and 22:00 to 24:00 hrs)
Peak / Off Peak Hours				
No. of blocks during the period	496	2480	496	2480
Installed Capacity (IC) (MW)	750.00	750.00	135.00	135.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	80.321500	381.459500	14.637500	67.055250
Plant Load Factor (PLF):	94.91	90.15	96.09	88.04

DATE : 06-11-2024


12/11/24
Superintending Engineer

SLDC, WBSETCL