



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/ 234

Dated : 11/6/24

To
The Director (Operation & Maintenance),
WBPDCL, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDCL generating stations for the month of May 2024.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDCL generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

Handwritten signature 11/6/24

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/

Dated :

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of **May 2024**.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **May 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-06/2024-25/ 234(1-8)

Dated: 11/6/24

Copy for kind information to:

1. The Managing Director, WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan
8. The Joint Director (Engg), WBERC, FD- 415A, Poura Bhavan, Sector – III, Kolkata – 700106.

Encl.: 01 Page.


Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in

STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025


WBDCL POWER STATIONS

May 2024

HIGH DEMAND SEASON

Item	BKTPP		BTPS_STAGE_I		BTPS_STAGE_II		DPL_STAGE_1		DPL_STAGE_2		KTPP		SGTPP_STAGE_I		SGTPP_STAGE_II		STPS	
	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK	SGS PEAK	SGS OFF PEAK
No. of blocks during the period	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480
Installed Capacity (IC) (MW)	1050.00	1050.00	60.00	60.00	215.00	215.00	300.00	300.00	250.00	250.00	840.00	840.00	600.00	600.00	1000.00	1000.00	500.00	500.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00	10.40	10.40	9.00	9.00	8.50	8.50	9.00	9.00	9.60	9.60	9.00	9.00	9.00	9.00	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	115.887930	569.525573	3.452844	16.173605	23.746715	116.514172	29.268719	146.179110	26.799447	132.372088	73.251435	341.469343	64.818903	322.557122	114.652970	565.370181	54.821821	266.435849
Plant Load Factor (PLF):	97.81	96.14	51.80	48.52	97.88	96.05	85.99	85.89	95.00	93.85	77.79	72.53	95.74	95.28	101.61	100.21	97.17	94.45

DATE : 11-06-2024


 11/06/24
 Divisional Engineer / Superintendent Engineer
 SLDC, WBSETCL