



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/37

Dated : 08.04.24

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of **March 2024**.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **March 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

[Handwritten Signature] 8/4/24

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbslde_power@yahoo.co.in, wbslde.enac@gmail.com, Web-site : www.wbslde.in



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2024-25/

Dated :

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub:Plant Load Factor (PLF) for WBPDC generating stations for the month of **March 2024**.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **March 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-06/2023-24/ 37 (1-8)

Dated: 08.09.24

Copy for kind information to:

1. The Managing Director, WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan
8. The Joint Director (Engg), WBERC, FD- 415A, Poura Bhavan, Sector – III, Kolkata – 700106.

Encl.: 01 Page.

Rm 8/4/24

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in

STATE LOAD DESPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
 (A Govt of W.B. Enterprise)

Plant Load Factor(PLF) of the generating station
 Financial Year : 2023-24

WBPDC POWER STATIONS
 March-2024
 LOW DEMAND SEASON

Item	BTPS-I		BTPS-II		STPS		K'TPS		BKTPP		SgTTP-I		SgTTP-II		DPL-I		DPL-II	
	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK
No. of blocks during the period	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480
Installed Capacity (IC) (MW)	60	60	215	215	500	500	840	840	1050	1050	600	600	1000	1000	300	300	250	250
Normative Auxiliary Consumption in percentage (AUX)	10.4	10.4	9	9	9	9	9.6	9.6	9	9	9	9	9	9	8.5	8.5	9	9
Scheduled Generation in MU (Summation of No. of blocks during the period)	5.553208	25.459517	24.577933	120.443745	56.087578	268.622352	86.306157	400.592770	119.250403	581.564265	67.455912	334.965545	117.448410	580.207693	31.004250	154.749550	26.232360	129.849725
Plant Load Factor(PLF):	83.30	76.38	101.31	99.29	99.41	95.22	91.66	85.09	100.65	98.17	99.63	98.95	104.08	102.84	91.09	90.93	92.99	92.06

DATE:

L
 08/09/24
 Divisional Engineer
 SLDC, WBSETCL