



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

*Office of the Chief Engineer*  
**State Load Despatch Centre**

**WBSETCL**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbslde.in](http://www.wbslde.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.  
E-Mail: CE : [ce.wbslde@gmail.com](mailto:ce.wbslde@gmail.com)/  
[ce.wbslde@wbsetcl.in](mailto:ce.wbslde@wbsetcl.in)  
Control Room: [wbslde@gmail.com](mailto:wbslde@gmail.com)  
Energy Account: [wbslde.enac@gmail.com](mailto:wbslde.enac@gmail.com)

Memo No: SLDC/HOW/B-30/2024-25/791

Dated : 04/12/2024

To  
The G M, HEL,  
Baneswarchak, Gopalchak,  
Haldia - 721658.

**Sub: Plant Load Factor (PLF) for the month of November 2024 i.r.o. HEL.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **November 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

*[Handwritten Signature]* 4/12/24

Encl : 01 (One) Page.

Chief Engineer, SLDC(WB).

**WBSETCL**

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091  
CIN No. U40101WB2007SGC113474, Website: [www.wbsetcl.in](http://www.wbsetcl.in)



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

**Office of the Chief Engineer**  
**State Load Despatch Centre**

**WBSETCL**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbsetcl.in](http://www.wbsetcl.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.  
E-Mail: CE : [ce.wbsetcl@gmail.com](mailto:ce.wbsetcl@gmail.com)/  
[ce.wbsetcl@wbsetcl.in](mailto:ce.wbsetcl@wbsetcl.in)  
Control Room: [wbsetcl@gmail.com](mailto:wbsetcl@gmail.com)  
Energy Account: [wbsetcl.enac@gmail.com](mailto:wbsetcl.enac@gmail.com)

Memo No: SLDC/HOW/B-30/2024-25/

Dated :

To  
The G M, HEL,  
Baneswarchak, Gopalchak,  
Haldia - 721658.

Sub: **Plant Load Factor (PLF) for the month of November 2024 i.r.o. HEL.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **November 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.


Sd/-  
( R. Chakraborty )  
Chief Engineer, SLDC(WB).

Memo No : SLDC/HOW/B-20/2024-25/791(1-2)  
Copy for kind information to:

Dated : 4/12/2024

1. The G M (S/O), CESC House, Annex Building, Chowringee Square, Kolkata - 700001
2. The Joint Director (Eng). WBERC, Plot No: AH/5(2<sup>nd</sup> and 4<sup>th</sup> Floor), Premises No: MAR16-1111 Action Area -I A, New Town, Kolkata-700163.

Encl : 01 (One) Page.

  
Chief Engineer, SLDC(WB).

**WBSETCL**

Registered Office: Vidhut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091  
CIN No. U40101WB2007SGC113474, Website: [www.wbsetcl.in](http://www.wbsetcl.in)

**STATE LOAD DISPATCH CENTRE  
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED  
(A Govt. of W.B. Enterprise)**

**Plant Load Factor (PLF) of the generating station**

**Financial Year : 2024-2025**

**STATION: HALDIA ENERGY LIMITED**

**November 2024**

**LOW DEMAND SEASON**

Item	HEL	
	SGS PEAK	SGS OFF PEAK
No. of blocks during the period	480	2400
Installed Capacity (IC) (MW)	600.00	600.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	67.130000	306.961240
Plant Load Factor (PLF):	102.46	93.70

*hel*  
04/12/24  
SE, SLDC