



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbsldc.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah – 711109.
E-Mail: CE : ce.wbsldc@gmail.com/
ce.wbsldc@wbsetcl.in
Control Room: wbsldc@gmail.com
Energy Account: wbsldc.enac@gmail.com

Memo No: SLDC/HOW/B-30/2024-25/ 893

Dated : 7/1/25.

To
The G M, HEL,
Baneswarchak, Gopalchak,
Haldia - 721658.

Sub: Plant Load Factor (PLF) for the month of December 2024 i.r.o. HEL.


Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **December 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.


Chief Engineer, SLDC(WB).

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in



West Bengal State Electricity Transmission Company Limited
(A Government of West Bengal Enterprise)

Office of the Chief Engineer
State Load Despatch Centre

WBSETCL

Telephones: (033) 2641-6570 (CE)
Fax: (033) 2688-5417/6232
(033) 2688-7693/7690, 9434910598 (Control Room)
(033) 2688-7186/6572 (Addl. CE)
(033) 2688-7698 (Energy Accounting)
Website: www.wbsldc.in

Andul Road, P.O. Danesh Seikh Lane,
Howrah - 711109.
E-Mail: CE : ce.wbsldc@gmail.com/
ce.wbsldc@wbsetcl.in
Control Room: wbsldc@gmail.com
Energy Account: wbsldc.enac@gmail.com

Memo No: SLDC/HOW/B-30/2024-25/

Dated :

To
The G M, HEL,
Baneswarchak, Gopalchak,
Haldia - 721658.

Sub: Plant Load Factor (PLF) for the month of December 2024 i.r.o. HEL.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **December 2024** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.


Sd/-
(R. Chakraborty)
Chief Engineer, SLDC(WB).

Memo No : SLDC/HOW/B-20/2024-25/ 393 (1-2)
Copy for kind information to:

Dated : 7/1/25.

1. The G M (S/O), CESC House, Annex Building, Chowringee Square, Kolkata - 700001
2. The Joint Director (Eng). WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.

Encl : 01 (One) Page.


Chief Engineer, SLDC(WB).

WBSETCL

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091
CIN No. U40101WB2007SGC113474, Website: www.wbsetcl.in

**STATE LOAD DISPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt. of W.B. Enterprise)**

Plant Load Factor (PLF) of the generating station

Financial Year : 2024-2025

STATION: HALDIA ENERGY LIMITED

December 2024

LOW DEMAND SEASON

Item	HEL	
	PEAK (17:00 to 21:00 hrs)	OFF PEAK (00:00 to 17:00 and 21:00 to 24:00 hrs)
Peak / Off Peak Hours		
No. of blocks during the period	496	2480
Installed Capacity (IC) (MW)	600.00	600.00
Normative Auxiliary Consumption in percentage (AUX):	9.00	9.00
Scheduled Generation in MU (Summation of No. of blocks during the period)	64.503946	278.844983
Plant Load Factor (PLF):	95.27	82.37

DATE : 03-01-2025


06/01/25
Superintending Engineer
SLDC, WBSETCL