

West Bengal State Electricity Transmission Company Limited (A Govt. of W.B. Enterprise)

Office of the Chief Engineer State Load Despatch Centre (W.B.), PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-30/2023-24/ 676

Dated: 0712-23

To The G M, HEL, Baneswarchak, Gopalchak, Haldia - 721658.

Sub: Plant Load Factor (PLF) for the month of November 2023 i.r.o. HEL.

Dear Sir.

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **November 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Dy 1/12/23

Encl: 01 (One) Page.

Chief Engineer, SLDC(WB).



West Bengal State Electricity Transmission Company Limited (A Govt. of W.B. Enterprise)

Office of the Chief Engineer State Load Despatch Centre (W.B.), PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-30/2023-24/

Dated:

To The G M, HEL, Baneswarchak, Gopalchak, Haldia - 721658.

Sub: Plant Load Factor (PLF) for the month of November 2023 i.r.o. HEL.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Haldia Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **November 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 (One) Page.

Sd/(R. Chakraborty)
Chief Engineer, SLDC(WB).

Memo No: SLDC/HOW/B-20/2023-24/676 (1-2) Copy for kind information to:

Dated: 07.12-23

Du 1 m/23

- 1. The G M (S/O), CESC House, Annex Building, Chowringee Square, Kolkata 700001
- 2. The Joint Director (Eng). WBERC, Plot No: AH/5(2nd and 4th Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.

Encl: 01 (One) Page.

Chief Engineer, SLDC(WB).

STATE LOAD DESPATCH CENTRE

WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED (A Govt of W.B. Enterprise)

Plant Load Factor(PLF) of the generating station Financial Year : 2023-24

STATION: HALDIA ENERGY LIMITED

November-2023

LOW DEMAND SEASON

Item	HEL	
	SG PEAK	SG OFF PEAK
No. of blocks during the period	480	2400
Installed Capacity (IC) (MW)	600	600
Normative Auxiliary Consumption in percentage (AUX):	9	9
Scheduled Generation in MU (Summation of No. of blocks during the period)	48.953204	217.540079
Plant Load Factor(PLF):	74.71	66.40

DATE:

Divisional Engineer SLDC,WBSETCL