



West Bengal State Electricity Transmission Company Limited  
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer  
State Load Despatch Centre (W.B.),  
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No : SLDC/HOW/B-31/2023-24/ 99

Dated : 11.05.23

To  
The Vice President (Commercial),  
Hiranmaye Energy Limited,  
Plot No. X -1, 2 & 3, Block-EP,  
Sector -V, Saltlake, Kolkata -700091.

Sub: Plant Load Factor for the month of April 2023 i.r.o. Hiranmaye Energy Limited.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **April 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

*Handwritten signature*  
11/5/23

Encl : 01 (One) Page.

Chief Engineer, SLDC(WB).

**WBSETCL**



**West Bengal State Electricity Transmission Company Limited**  
(A Govt. of W.B. Enterprise)

*Office of the Chief Engineer*  
State Load Despatch Centre (W.B.),  
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No : SLDC/HOW/B-31/2023-24/

Dated :

To  
The Vice President (Commercial),  
Hiranmaye Energy Limited,  
Plot No. X -1, 2 & 3, Block-EP,  
Sector –V, Saltlake, Kolkata -700091.

**Sub: Plant Load Factor for the month of April 2023 i.r.o. Hiranmaye Energy Limited.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **April 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.

Sd/-  
( R.Chakraborty )  
Chief Engineer, SLDC(WB).

Memo No: SLDC/HOW/B-25/2023-24/ 99 (i-iii)  
Copy for kind information to:

Dated : 11.05.23.

1. The Director (Operations), WBSETCL, 8<sup>th</sup> Floor, Vidyut Bhavan, Kolkata – 700 091.
2. The Director (RT), WBSEDCL, 7<sup>th</sup> Floor, Vidyut Bhavan, Kolkata – 700 091.
3. The C.E (PTP), WBSEDCL, 7<sup>th</sup> floor Vidyut Bhavan, B-Block, Sector –II, Kolkata-91.

Encl : 01 (One) Page.

804 u/s/23  
Chief Engineer, SLDC(WB).

**WBSETCL**

**STATE LOAD DESPATCH CENTRE, WBSETCL**  
**WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**  
(A Govt of W.B. Enterprise)

**Plant Load Factor(PLF) of the generating station**  
**Financial Year : 2023-24**

**STATION: HIRANMOYEE ENERGY LIMITED**  
**April-2023**  
**HIGH DEMAND SEASON**

Item	HirEL	
	SG PEAK	SG OFF PEAK
No. of blocks during the period	480	2400
Installed Capacity (IC) (MW)	300	300
Normative Auxiliary Consumption in percentage (%)	10.5	10.5
Scheduled generation (summation of no. of blocks during the period)	57369.484	289679.76
<b>Plant Load Factor(PLF):</b>	<b>44.51387647</b>	<b>44.95340782</b>

DATE:

  
11/05/23  
Divisional Engineer  
SLDC, WBSETCL