



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2023-24/ 113

Dated : 16.05.23

To
The Director (Operation & Maintenance),
WBPDCL, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098.

Sub: Revised Plant Load Factor (PLF) for WBPDCL generating stations for the month of April 2023.

Dear Sir,

With reference to above, Revised Plant Load Factor (PLF) calculation for WBPDCL generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **April 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

RDM 16/5/23
Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbslde_power@yahoo.co.in, wbslde.enac@gmail.com, Web-site : www.wbslde.in



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2023-24/

Dated :

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Revised Plant Load Factor (PLF) for WBPDC generating stations for the month of April 2023.

Dear Sir,

With reference to above, Revised Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **April 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-06/2023-24/ 113 (i-via)

Dated: 16/5/23

Copy for kind information to:

1. The Managing Director, WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSEDCL, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan

Encl.: 01 Page.

Ru 16/5/23
Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbslde_power@yahoo.co.in, wbslde.enac@gmail.com, Web-site : www.wbslde.in

STATE LOAD DESPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
 (A Govt of W.B. Enterprise)

Plant Load Factor(PLF) of the generating station
 Financial Year : 2023-24

WBPDCL POWER STATIONS
 April-2023
 HIGH DEMAND SEASON

REV-01

Item	BTPS-I		BTPS-II		STPS		KTPS		BKTPP		SgTPP-I		SgTPP-II		DPL-I		DPL-II	
	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK
No. of blocks during the period	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400
Installed Capacity (IC) (MW)	60	60	215	215	500	500	840	840	1050	1050	600	600	1000	1000	300	300	250	250
Normative Auxiliary Consumption in percentage (AUX):	10.4	10.4	9	9	9	9	9.6	9.6	9	9	9	9	9	9	8.5	8.5	9	9
Scheduled Generation in MU (Summation of No. of blocks during the period)	3.402344	15.605290	21.570107	104.484022	53.496700	249.768338	71.694051	345.780399	107.470000	518.080019	61.540000	295.582530	113.200000	552.707187	21.761500	102.314723	24.834000	123.661955
Plant Load Factor(PLF):	52.74	48.38	91.87	89.01	97.98	91.49	78.68	75.89	93.73	90.37	93.93	90.23	103.66	101.23	66.06	62.12	90.97	90.59

hml 16/05/23
 Divisional Engineer
 SLD, WBSETCL

DATE: