



**West Bengal State Electricity Transmission Company Limited**  
(A Govt. of W.B. Enterprise)

*Office of the Chief Engineer*  
State Load Despatch Centre (W.B.),  
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2023-24/ 271

Dated : 07.07.23

To  
The Director (Operation & Maintenance),  
WBPDC, Bidyut Unnayan Bhavan,  
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of **June 2023**.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **June 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

*[Signature]* 7/7/23  
Chief Engineer, SLDC (WB).

**WBSETCL**

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)  
Fax No 26886232, 26885417, 26887698 E-mail Id : [wbsldc\\_power@yahoo.co.in](mailto:wbsldc_power@yahoo.co.in), [wbsldc.enac@gmail.com](mailto:wbsldc.enac@gmail.com), Web-site : [www.wbsldc.in](http://www.wbsldc.in)



West Bengal State Electricity Transmission Company Limited  
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer  
State Load Despatch Centre (W.B.),  
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2023-24/

Dated :

To  
The Director (Operation & Maintenance),  
WBPDC, Bidyut Unnayan Bhavan,  
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of **June 2023**.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **June 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-  
( R. Chakraborty )  
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-06/2023-24/

271(i-viii)

Dated: 07.07.23

Copy for kind information to:

1. The Managing Director, WBSETCL, 8<sup>th</sup> Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8<sup>th</sup> Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSEDCL, 7<sup>th</sup> Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSEDCL, 7<sup>th</sup> Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan
8. The Joint Director (Engg), WBERC, FD- 415A, Poura Bhavan, Sector – III, Kolkata – 700106.

Encl.: 01 Page.

Ru 7/7/23

Chief Engineer, SLDC (WB).

**WBSETCL**

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)  
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc\_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in

**STATE LOAD DESPATCH CENTRE**  
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED  
(A Govt of W.B. Enterprise)

**Plant Load Factor(PLF) of the generating station**  
Financial Year : 2023-24

WBPDCL POWER STATIONS  
June-2023  
HIGH DEMAND SEASON

Item	BTPS-I		BTPS-II		STPS		KTPS		BKTPP		SgTPP-I		SgTPP-II		DPL-I		DPL-II	
	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK
No. of blocks during the period	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480	496	2480
Installed Capacity (IC), (MW)	60	60	215	500	500	840	840	1050	1050	600	600	1000	1000	300	300	300	250	250
Normative Auxiliary Consumption in percentage (AUX):	10.4	10.4	9	9	9	9.6	9.6	9	9	9	9	9	9	8.5	8.5	8.5	9	9
Scheduled Generation in MW (Summation of No. of blocks during the period)	0.530500	2.796473	21.412364	101.985170	45.782750	220.865476	243.182046	95.290019	449.613481	54.794563	262.875584	94.778031	438.635991	14.008500	66.470969	20.154000	97.577400	97.577400
<b>Plant Load Factor(PLF):</b>	<b>7.96</b>	<b>8.39</b>	<b>88.26</b>	<b>84.07</b>	<b>81.15</b>	<b>78.29</b>	<b>63.14</b>	<b>80.43</b>	<b>75.90</b>	<b>80.93</b>	<b>77.68</b>	<b>83.99</b>	<b>77.73</b>	<b>41.16</b>	<b>39.06</b>	<b>71.44</b>	<b>68.18</b>	<b>68.18</b>

DATE:

*Handwritten signature*  
07/07/23

Divisional Engineer  
SLOC,WBSETCL