



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2023-24/ 677

Dated : 07.12.23

To
The Director (Operation & Maintenance),
WBDCL, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBDCL generating stations for the month of **November 2023**.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBDCL generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **November 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl.: 01 Page.

Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in



West Bengal State Electricity Transmission Company Limited
(A Govt. of W.B. Enterprise)

Office of the Chief Engineer
State Load Despatch Centre (W.B.),
PO: Danesh Sk. Lane, Howrah – 711 109.

Memo No: SLDC/HOW/B-28/2023-24/

Dated :

To
The Director (Operation & Maintenance),
WBPDC, Bidyut Unnayan Bhavan,
3/C, L.A. Block, Sector – III, Bidhannagar, Kolkata – 700 098

Sub: Plant Load Factor (PLF) for WBPDC generating stations for the month of November 2023.

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for WBPDC generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **November 2023** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 Page.

Sd/-
(R. Chakraborty)
Chief Engineer, SLDC (WB).


Memo No: SLDC/HOW/B-06/2023-24/ 677 (1-3)

Dated: 07.12.23

Copy for kind information to:

1. The Managing Director, WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
2. The Director (Operations), WBSETCL, 8th Floor, Bidyut Bhavan, Kolkata – 700 091.
3. The Director (RT), WBSLDC, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
4. The Director (F&A), WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
5. The Director (RA) & Company Secretary, WBPDC, Bidyut Unnayan Bhavan, 3/C, L.A. Block, Sector – III, Kolkata – 700 098.
6. The Chief Engineer (PT&P), WBSLDC, 7th Floor, Bidyut Bhavan, Kolkata – 700 091.
7. The DGM (Commercial), DPL Administrative Building, Durgapur – 713 201, Dist: Burdwan
8. The Joint Director (Engg), WBERC, FD- 415A, Paura Bhavan, Sector – III, Kolkata – 700106.

Encl.: 01 Page.


Chief Engineer, SLDC (WB).

WBSETCL

Telephone No : 26416570 (CE), 26416572(Addl.CE), 26887636 (Energy Accounting), 26416574, 26887693 (Control Room)
Fax No 26886232, 26885417, 26887698 E-mail Id : wbsldc_power@yahoo.co.in, wbsldc.enac@gmail.com, Web-site : www.wbsldc.in

STATE LOAD DESPATCH CENTRE
WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
(A Govt of WB. Enterprise)

Plant Load Factor(PLF) of the generating station
Financial Year : 2023-24

WE PPOOL POWER STATIONS
No: November-2023
LOW DEMAND SEASON

Item	BTPS-I		BTPS-II		STPS		KTPS		BKTPP		SgTPP-I		SgTPP-II		DPL-I		DPL-II	
	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK	SG PEAK	SG OFF PEAK
No. of blocks during the period	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400	480	2400
Installed Capacity (IC) (MW)	60	60	215	215	500	500	840	840	1050	1050	600	600	1000	1000	300	300	250	250
Not native Auxiliary Consumption in percentage (AUX)	10.4	10.4	9	9	9	9	9.6	9.6	9	9	9	9	9	9	8.5	8.5	8	9
Self deduced Generation in MU	4.883886	18.310378	22.628023	109.844003	56.155506	261.243556	82.125820	370.171875	118.145000	572.438319	61.669325	293.260284	95.141409	433.641713	4.497330	20.903110	18.864500	94.637957
Plant Load Factor(PLF):	75.70	58.77	96.38	93.57	102.95	95.89	90.13	81.25	101.30	99.85	94.12	89.52	87.13	79.42	13.85	12.89	69.10	69.33

Divisional Engineer
S.D.C. WBSECL.

lm
07/12/23

DATE: