

State Load Despatch Centre

Import of West Bengal Transfer Capability for SEPTEMBER,2024

Issue Date: 21.08.24

Issue Time: 16:00 hrs

Revision No. 00

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st SEPTEMBER 2024 to 30th SEPTEMBER 2024	00-12 hrs	8167	450	7717				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11882 MW Gen 6534
1st SEPTEMBER 2024 to 30th SEPTEMBER 2024	12- 16 hrs	7996	450	7546				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11166 MW Gen 5634
1st SEPTEMBER 2024 to 30th SEPTEMBER 2024	16-00 hrs	8167	450	7717				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11882 MW Gen 6534
Limiting Constraints		1) Tripping of 400 kV JEERAT-S'GRM ckt creating constraints in-315 MVA ICT at JEERAT= 323 MVA for CESC peak case(12.00-16.00). 2) Tripping of 400 kV GOKARNA-PURNEA ckt creating constraints in-315 MVA ICT at SGTPP= 317 MVA for WBSEDCL peak case. 3) As per LGBR there is no constraints for export in SEPTEMBER'24.						

Banerjee 21-08-24

Additional Chief Engineer
SLDC,WBSETCL