

State Load Despatch Centre
Import of West Bengal Transfer Capability for AUGUST, 2024

Issue Date: 29-7-24

Issue Time: 14:00 hrs

Revision No. 00

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st AUGUST 2024 to 31st AUGUST 2024	00-12 hrs	8231	450	7781				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11567 MW Gen 6260
1st AUGUST 2024 to 31st AUGUST 2024	12- 16 hrs	7980	450	7530				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 10875 MW Gen 5800
1st AUGUST 2024 to 31st AUGUST 2024	16-00 hrs	8231	450	7781				TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11567 MW Gen 6260
Limiting Constraints		1) Tripping of 400 kV JEERAT-S'GRM ckt creating constraints in-315 MVA ICT at JEERAT= 322 MVA for CESC peak case(12.00-16.00). 2) Tripping of 400 kV JEERAT-S'GRM ckt creating constraints in-315 MVA ICT at JEERAT= 320 MVA for WBSEDCL peak case. 3) As per LGBR there is no constraints for export in JUNE'24.						

Banerjee 29-07-24
Additional Chief Engineer
SLDC, WBSETCL

Additional Chief Engineer
STATE LOAD DESPATCH CENTRE
WBSETCL, HOWRAH