



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

**Office of the Chief Engineer**  
**State Load Despatch Centre**

**WBSETCL**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbslde.in](http://www.wbslde.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.  
E-Mail: CE : [ce.wbslde@gmail.com](mailto:ce.wbslde@gmail.com)/  
[ce.wbslde@wbsetcl.in](mailto:ce.wbslde@wbsetcl.in)  
Control Room: [wbslde@gmail.com](mailto:wbslde@gmail.com)  
Energy Account: [wbslde.enac@gmail.com](mailto:wbslde.enac@gmail.com)

Memo No : SLDC/HOW/B-31/2025-26/ 475

Dated : 6/8/25

To  
The Vice President (Commercial),  
Hiranmaye Energy Limited,  
Plot No. X -1, 2 & 3, Block-EP,  
Sector -V, Saltlake, Kolkata -700091.

**Sub: Plant Load Factor for the month of June 2025 i.r.o. Hiranmaye Energy Limited.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **June 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl : 01 (One) Page.

*RM 6/8/25*  
Chief Engineer, SLDC(WB)

**WBSETCL**

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091  
CIN No. U40101WB2007SGC113474, Website: [www.wbsetcl.in](http://www.wbsetcl.in)



**West Bengal State Electricity Transmission Company Limited**  
(A Government of West Bengal Enterprise)

**Office of the Chief Engineer**  
**State Load Despatch Centre**

**WBSETCL**

Telephones: (033) 2641-6570 (CE)  
Fax: (033) 2688-5417/6232  
(033) 2688-7693/7690, 9434910598 (Control Room)  
(033) 2688-7186/6572 (Addl. CE)  
(033) 2688-7698 (Energy Accounting)  
Website: [www.wbslde.in](http://www.wbslde.in)

Andul Road, P.O. Danesh Seikh Lane,  
Howrah – 711109.  
E-Mail: CE : [ce.wbslde@gmail.com](mailto:ce.wbslde@gmail.com)/  
[ce.wbslde@wbsetcl.in](mailto:ce.wbslde@wbsetcl.in)  
Control Room: [wbslde@gmail.com](mailto:wbslde@gmail.com)  
Energy Account: [wbslde.enac@gmail.com](mailto:wbslde.enac@gmail.com)

Memo No : SLDC/HOW/B-31/2025-26/

Dated :

To  
The Vice President (Commercial),  
Hiranmaye Energy Limited,  
Plot No. X -1, 2 & 3, Block-EP,  
Sector –V, Saltlake, Kolkata -700091.

**Sub: Plant Load Factor for the month of June 2025 i.r.o. Hiranmaye Energy Limited.**

Dear Sir,

With reference to above, Plant Load Factor (PLF) calculation for Hiranmaye Energy Limited generating stations under ABT scheme as per Terms and Condition of Tariff (Fourth Amendment) Regulations, 2023 of WBERC dated 13.03.2023 for the month of **June 2025** are hereby sent to your end for further necessary action please.

Thanking you,

Yours faithfully,

Encl: 01 (One) Page.

Sd/-  
( R.Chakraborty )  
Chief Engineer, SLDC (WB).

Memo No: SLDC/HOW/B-25/2025-26/ 475 (1-4)  
Copy for kind information to:

Dated: 6/8/25

1. The Director (Operations), WBSETCL, 8<sup>th</sup> Floor, Vidyut Bhavan, Kolkata – 700 091.
2. The Director (RT), WBSEDCL, 7<sup>th</sup> Floor, Vidyut Bhavan, Kolkata – 700 091.
3. The C.E (PTP), WBSEDCL, 7<sup>th</sup> floor Vidyut Bhavan, B-Block, Sector –II, Kolkata-91.
4. The Joint Director (Eng). WBERC, Plot No: AH/5(2<sup>nd</sup> and 4<sup>th</sup> Floor), Premises No: MAR16-1111 Action Area -1 A, New Town, Kolkata-700163.

Encl : 01 (One) Page.

  
Chief Engineer, SLDC(WB)

**WBSETCL**

Registered Office: Vidyut Bhawan, Block - DJ, Sector - II, Bidhannagar, Kolkata - 700091  
CIN No. U40101WB2007SGC113474, Website: [www.wbsetcl.in](http://www.wbsetcl.in)

**STATE LOAD DISPATCH CENTRE**  
**WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**  
(A Govt. of W.B. Enterprise)

**Plant Load Factor (PLF) of the generating station**

**Financial Year : 2025-2026**


**STATION: HIRANMAYE ENERGY LIMITED**

**July 2025**

**LOW DEMAND SEASON**

Item	HIREL	
	PEAK	OFF PEAK
Peak / Off Peak Hours	( 00:00 to 01:00 and 21:00 to 24:00 hrs)	( 01:00 to 21:00 hrs)
No. of blocks during the period	496	2480
Installed Capacity (IC) (MW)	300.00	300.00
Normative Auxiliary Consumption in percentage (AUX):	10.50	10.50
Scheduled Generation in MU (Summation of No. of blocks during the period)	25.733546	119.011491
Plant Load Factor (PLF):	77.29	71.49

DATE : 05-08-2025

  
Superintending Engineer

SLDC,WBSETCL